

[Federal Register: June 26, 2006 (Volume 71, Number 122)]

[Corrections]

[Page 36394-36395]

From the Federal Register Online via GPO Access [wais.access.gpo.gov]

[DOCID:fr26jn06-110]

[[Page 36394]]

ENVIRONMENTAL PROTECTION AGENCY

40 CFR Parts 60, 63, 85, 90, 1048, 1065, and 1068

[EPA-HQ-OAR-2005-0030, FRL-8176-1]

RIN 2060-AM81 and 2060-AN62

Standards of Performance for Stationary Spark Ignition Internal Combustion Engines and National Emission Standards for Hazardous Air Pollutants for Reciprocating Internal Combustion Engines

Correction

In proposed rule document 06-4919 beginning on page 33804 in the issue of Monday, June 12, 2006, make the following corrections:

1. On page 33808, in Table 1, in the table heading, in the first line, ``>19'' should read ``<=19''.
2. On page 33809, in Table 3, in the second column, in the third entry, ``HP<=500'' should read ``HP>=500''.
3. On the same page, in the same table, in the same column, in the fifth entry, ``HP>=500'' should read ``HP<500''.
4. On pages 33810 and 33811, Table 4 is being reprinted in its entirety to read as follows:

Table 4.--Emission Standards for Stationary RICE < =500 HP Located at Major Sources of HAP Emissions and

Stationary RICE Located at Area Sources of HAP Emissions

Engine type and fuel Emission standards	Maximum engine power	Manufacture date
Existing All Fuels and All Types. Emission Reduction.	All Sizes.....	No
New/Reconstructed SI.....	< =25 HP.....	January 1, 2008.....
subpart JJJJ.		
New/Reconstructed SI Gasoline and	25< HP< 500.....	January 1, 2008.....
Meet 40 CFR part 60		

Rich Burn LPG. HP>=500..... July 1,
 2007..... subpart JJJJ.
 New/Reconstructed Non-Emergency 25< HP< 500 a..... January 1,
 2008..... 1.0 g/HP-hr NMHC.
 SI Natural Gas.
 and

New/Reconstructed Non-Emergency January 1,
 2011..... 0.7 g/HP-hr NMHC.
 SI Lean Burn LPG b.
 New/Reconstructed Non-Emergency HP>=500..... July 1,
 2007..... 1.0 g/HP-hr NMHC
 SI Natural Gas.
 and

New/Reconstructed Non-Emergency July 1,
 2010..... 0.7 g/HP-hr NMHC.
 SI Lean Burn LPG.
 New/Reconstructed Non-Emergency 250< HP < =500..... January 1,
 2008..... 93% CO Reduction or
 SI 4SLB at Major Sources (except
 14 ppmvd
 landfill and digester gas) b.
 formaldehyde.
 CI All Fuels..... All Sizes..... 2007+ Model
 Year..... Meet 40 CFR part 60

subpart IIII.
 Landfill/Digester Gas..... HP< 500..... January 1,
 2008..... 1.0 g/HP-hr NMHC.
 HP>=500..... July 1,
 2007..... 1.0 g/HP-hr NMHC.
 Emergency SI..... All Sizes..... January 1,
 2009..... 1.0 g/HP-hr NMHC.

 a Stationary SI natural gas and lean burn LPG engines between 19 and 37 KW (25 and 50 HP) may comply with the requirements of Table 2 of this preamble, instead of this table, as applicable.
 b New and reconstructed non-emergency 4SLB engines at major sources with a site rating between 250 and 500 HP are not required to meet the 1.0 and 0.7 g/HP-hr NMHC emission standards.

[[Page 36395]]

Table 3 to Subpart ZZZZ of Part 63 [Corrected]

- 5. On page 33844, in Table 3 to Subpart ZZZZ of Part 63, in the table heading, in the second line, ``>500 HP'' should read ``<=500 HP''.
- 6. On page 33845, in the same table, in the table heading, in the second line, ``>500 HP'' should read ``<=500 HP''.

[FR Doc. C6-4919 Filed 6-23-06; 8:45 am]

BILLING CODE 1505-01-D